

FINAL PROJECT

FOR THE CONSTRUCTION OF
A PHOTOVOLTAIC SYSTEM OF 343,2 kWp

NAMED

Photovoltaic system SolarLands

SITE IN THE CIY OF

Alacant

A-79

03114 - Alicante

CUSTOMER:

John Smith SolarLands

Alcant

A-79 03114 - Padova

Attachments:

- *Single-line diagram of the plant;*
- *Planimetric scheme.*

DATE

25/10/2017

THE TECHNICAL

*Black Joe
Sun Power Ltd*

PLANT GENERAL INFORMATION

This project relates to the construction of a plant producing electricity through photovoltaic conversion, with a peak power equal to 343,2 kWp.

| CUSTOMER | |
|----------------------|----------------------------|
| Customer: | Smith John SolarLands |
| Address: | A-79 03114 Alcant |
| Tax code/VAT number: | 01245632974 |
| Phone number: | 049 874561; +44 049 874561 |
| Fax: | |
| E-mail: | john@solarlands.com |

SITE OF INSTALLATION

The plant Photovoltaic system SolarLands has the following characteristics: Photovoltaic system ground mounted.

| DATA ON THE LOCATION OF INSTALLATION | |
|--------------------------------------|--------------------|
| Location: | Alacant 03114 A-79 |
| Latitude: | 038° 18'55" |
| Longitude: | 000° -32' -57" |
| Altitude: | 31 m |
| Source climate data: | Electro Graphics |
| Albedo: | View table |

| ALBEDO TABLE | | |
|--------------|------|-------------|
| January | 20 % | Dry grass |
| February | 20 % | Dry grass |
| March | 26 % | Green grass |
| April | 26 % | Green grass |
| May | 26 % | Green grass |
| June | 26 % | Green grass |
| July | 26 % | Green grass |
| August | 26 % | Green grass |
| September | 20 % | Dry grass |
| October | 30 % | Dead leaves |
| November | 20 % | Dry grass |
| Dicember | 30 % | Dead leaves |

DIMENSIONING OF THE PLANT

The amount of producible electricity will be calculated on the basis of radiometric data indicated in the standard ElectroGraphics.

For plants will meet the following conditions *(to be done for each "photovoltaic generator", understood as a set of photovoltaic modules with the same slope and same orientation)*:

at startup of the photovoltaic system, the relationship between the energy or power produced into alternating current and the energy or power producible in alternating current (determined as a function of solar radiation incident on the surface of the modules, rated system and the operating temperature of the modules) must be at least greater than 0.78 when using inverter power up to 20 kW and 0.8 in the case of using higher power inverters, under the conditions of measurement and calculation methods described in EN 60904-2.

It will not be admitted to the parallel strings that are not perfectly identical to each other for exposition, and/or brand, and/or model, and/or number of modules used. Each module, then, will be equipped with bypass diode.

DESCRIPTION OF THE PLANT

The photovoltaic system consists of No. 1 photovoltaic generators composed of No. 1320 photovoltaic modules and No. 3 inverters with type of realization Ground-mounted .

The total rated power is 343,2 kWp for an annual production of 490.119,2 kWh distributed over an area of 2.125,2 m².

Method of connection to the network Threephase in Medium voltage with power supply voltage 20.000 V.

EMISSIONS

The plant reduces emissions into the atmosphere annually as reported in the following table:

| Equivalent thermal generation | |
|--|-----------|
| Sulphur dioxide (SO ₂): | 343,49 kg |
| Oxides of nitrogen (NO _x): | 432,41 kg |
| Powders: | 15,34 kg |
| Carbon dioxide (CO ₂): | 255,61 t |

| Equivalent geothermal generation | |
|---|-----------|
| Hydrogen sulfide (H ₂ S) (geothermal fluid): | 15,02 kg |
| Carbon dioxide (CO ₂): | 2,89 t |
| Tonne of oil equivalent (TOE): | 112,73 TO |

SOLAR RADIATION

The evaluation of the available solar resource was carried out according to standard ElectroGraphics, taking as reference the location that has historical data of solar radiation in the immediate vicinity of Alacant.

TABLE OF SOLAR RADIATION ON HORIZONTAL

| Month | Total per day [MJ/m ²] | Total per month [MJ/m ²] |
|-----------|---------------------------------------|---|
| January | 8,35 | 258,85 |
| February | 11,34 | 317,52 |
| March | 15,3 | 474,3 |
| April | 19,26 | 577,8 |
| May | 21,64 | 670,84 |
| June | 24,37 | 731,1 |
| July | 24,62 | 763,22 |
| August | 21,71 | 673,01 |
| September | 16,67 | 500,1 |
| October | 12,2 | 378,2 |
| November | 8,68 | 260,4 |
| Dicember | 7,13 | 221,03 |

ENERGY PRODUCTION TABLE

| Month | Total per day [kWh] | Total per month [kWh] |
|-----------|------------------------|--------------------------|
| January | 879,631 | 27268,552 |
| February | 1097,969 | 30743,143 |
| March | 1364,859 | 42310,643 |
| April | 1563,374 | 46901,216 |
| May | 1637,679 | 50768,034 |
| June | 1785,178 | 53555,335 |
| July | 1828,045 | 56669,389 |
| August | 1713,396 | 53115,275 |
| September | 1428,367 | 42851,001 |
| October | 1153,507 | 35758,728 |
| November | 892,05 | 26761,503 |
| Dicember | 755,367 | 23416,388 |

EXPOSURE

The photovoltaic system consists of 1 distributed generators on 1 exposures as defined below:


| Description | Type of construction | Type of installation | Azimut | Tilt | Shad. |
|------------------|----------------------|----------------------|--------|------|--------|
| On ground system | Ground-mounted | Fixed tilt | 0° | 27° | 2,43 % |

On ground system

On ground system will be exposed with a $0,00^\circ$ orientation (azimuth) with respect to the south and will be exposed with a $27,00^\circ$ tilt respect of the horizontal.


The energy production of the exposure On ground system is conditioned by shading factors that determine a reduction of solar radiation as far 2,43 %.

SHADING DIAGRAM



SOLAR RADIATION DIAGRAM

Mediumdaily solarradiationonn



SOLAR RADIATION TABLE

| Month | Direct Radiation [kWh/m ²] | Diffuse Radiation [kWh/m ²] | Reflected Radiation [kWh/m ²] | Total per day [kWh/m ²] | Total per month [kWh/m ²] |
|-----------|--|---|---|-------------------------------------|---------------------------------------|
| January | 2,346 | 0,825 | 0,025 | 3,196 | 99,071 |
| February | 2,838 | 1,081 | 0,034 | 3,952 | 110,666 |
| March | 3,436 | 1,399 | 0,06 | 4,895 | 151,74 |
| April | 3,783 | 1,728 | 0,075 | 5,586 | 167,588 |
| May | 3,781 | 1,974 | 0,085 | 5,84 | 181,031 |
| June | 4,301 | 1,967 | 0,096 | 6,364 | 190,907 |
| July | 4,565 | 1,855 | 0,097 | 6,517 | 202,027 |
| August | 4,308 | 1,723 | 0,085 | 6,117 | 189,625 |
| September | 3,548 | 1,517 | 0,05 | 5,116 | 153,466 |
| October | 2,901 | 1,184 | 0,055 | 4,14 | 128,329 |
| November | 2,308 | 0,895 | 0,026 | 3,229 | 96,868 |
| December | 1,946 | 0,764 | 0,032 | 2,742 | 85,006 |

SUPPORT STRUCTURES

The modules will be mounted on the galvanized steel supports with a tilt of 27°, will all have the same exposure. The anchors of the structure will need to withstand winds up to speeds of 120 km/h.

Generator ground mounted

Generator ground mounted. Modules face south and tilt 27°; mounted on support structures fixed-tilt.

The generator consists of No. 1320 type modules Polycrystalline silicon with an estimated useful life of more than 20 years and degradation of production due to aging of 0,8 %% per annum.

| CHARACTERISTICS OF PHOTOVOLTAIC GENERATOR | |
|---|----------------|
| Type of realization: | Ground-mounted |
| Number of modules: | 1320 |
| Number of inverter: | 3 |
| Rated power: | 343200 W |
| Performance ratio: | 79,3 % |

| CONSTRUCTION DATA OF MODULES | |
|------------------------------|-------------------------|
| Manufacturer: | CSI CANADIAN SOLAR INC |
| Series / Ref-mark: | CS6P CS6P-260P |
| Manufacturing technology: | Polycrystalline silicon |
| Electrical characteristics | |
| Maximum power: | 260 W |
| Efficiency: | 16,2 % |
| Rated voltage: | 30,4 V |
| No-load voltage: | 37,5 V |
| Rated current: | 8,6 A |
| Short-circuit current: | 9,1 A |
| Dimensions | |
| Dimensions: | 982 mm x 1638 mm |
| Weight: | 18,5 kg |

The voltage values at various operating temperatures (minimum, maximum and operating) fall within the acceptable range allowed by the inverter.

The electrical line that arrives from photovoltaic modules is grounding by appropriate Surge Protection Devices with "out of service" optical indicator, to guar.

ENERGY CONVERSION SYSTEM

The conversion system consists of static converters (inverters).

The converter DC/AC used is fit for the transfer of power from the PV array to the network of the distributor, in accordance with the technical regulatory requirements and safety standards. The values of input voltage and input current of this device are compatible with those of the respective photovoltaic field, while the values of output voltage and output frequency are compatible with those of the network that is connected to the system.

The main features of the the conversion system are:

- Forced switching inverter with PWM technique (pulse-width modulation), no clock and / or internal reference of voltage or current, similar to "system is not adequate for the voltage and frequency in the normal range".
- DC input side of the photovoltaic generator manageable with poles not connected to the ground, ie IT system.
- Compliance with general standards on EMC and RF emission limitation: according to EN 55014-1, EN 55011, EN 50082-1.
- Protections for disconnection from the network for values outside the threshold voltage and line frequency and overcurrent fault in accordance with the requirements of the local electrical distributor. Automatic reset of the protections for predisposition to automatic start.
- CE Mark compliance.
- Degree of protection suitable to the location near the PV field (IP65).
- Declaration conformity of the product to applicable technical regulations, issued by the manufacturer, with reference to standard tests performed on the component at an authorized and recognized certification body.
- Input voltage range appropriate to the output voltage of the PV generator.
- Maximum efficiency $\geq 90\%$ at 70% of the nominal power.

The conversion system is composed of 3 inverter.

| Construction data of the inverters | |
|------------------------------------|-----------------------|
| Manufacturer: | ABB Spa |
| Series / Ref-mark: | PLUS PVI-110.0-TL M-M |
| Trackers: | 2 |
| Inputs per tracker: | 1 |
| Electrical characteristics | |
| Rated power: | 110 kW |
| Maximum power: | 112,8 kW |
| Maximum power per tracker: | 56,4 kW |
| Rated voltage: | 850 V |
| Maximum voltage: | 1000 V |
| Minimum voltage per tracker: | 485 V |
| Maximum voltage per tracker: | 950 V |
| Output rated voltage: | 320 Vac |
| Rated current: | 246 A |
| Maximum current: | 246 A |
| Maximum current per tracker: | 123 A |
| Efficiency: | 0,98 |

| Inverter 1 | MPPT 1 | MPPT 2 |
|--------------------|------------------|------------------|
| Modules in series: | 20 | 20 |
| Parallel strings: | 11 | 11 |
| Exposures: | On ground system | On ground system |
| MPP voltage (STC): | 608 V | 608 V |

| | | |
|---------------------|-----|-----|
| Numeber of modules: | 220 | 220 |
|---------------------|-----|-----|

| Inverter 2 | MPPT 1 | MPPT 2 |
|---------------------|------------------|------------------|
| Modules in series: | 20 | 20 |
| Parallel strings: | 11 | 11 |
| Exposures: | On ground system | On ground system |
| MPP voltage (STC): | 608 V | 608 V |
| Numeber of modules: | 220 | 220 |

| Inverter 3 | MPPT 1 | MPPT 2 |
|---------------------|------------------|------------------|
| Modules in series: | 20 | 20 |
| Parallel strings: | 11 | 11 |
| Exposures: | On ground system | On ground system |
| MPP voltage (STC): | 608 V | 608 V |
| Numeber of modules: | 220 | 220 |

DIMENSIONING

The power rating of the generator is given by:

$$P = P_{\text{module}} * N^{\circ} \text{modules} = 260 \text{ W} * 1320 = 343200 \text{ W}$$

The total energy produced by the STC (radiation modules of 1000 W/m² at 25 °C of temperature) is calculated as:

| Exposure | N° modules | Solar radiation [kWh/m ²] | Energy [kWh] |
|------------------|------------|---------------------------------------|--------------|
| On ground system | 1320 | 1.800,15 | 617.811,27 |

$$E = E_n * (1 - \text{Disp}) = 490119,2 \text{ kWh}$$

where

Disp = Power losses obtained from:

| | |
|-------------------------------------|---------------|
| Shading losses: | 3,0 % |
| Temperature increasing losses: | 6,7 % |
| Mismatching losses: | 5,0 % |
| DC current losses: | 0,6 % |
| Other losses (dirt, tolerances...): | 5,0 % |
| Conversion losses: | 2,3 % |
| Total losses: | 20,7 % |

SHADING LOSSES TABLE

| Month | Without obstacles [kWh] | Real production [kWh] | Losses [kWh] |
|-----------|-------------------------|-----------------------|--------------|
| January | 27799,0 | 27268,6 | -1,9 % |
| February | 31052,6 | 30743,1 | -1,0 % |
| March | 42577,9 | 42310,6 | -0,6 % |
| April | 47024,7 | 46901,2 | -0,3 % |
| May | 50796,8 | 50768,0 | -0,1 % |
| June | 53568,0 | 53555,3 | 0,0 % |
| July | 56688,2 | 56669,4 | 0,0 % |
| August | 53208,1 | 53115,3 | -0,2 % |
| September | 43062,1 | 42851,0 | -0,5 % |
| October | 36008,7 | 35758,7 | -0,7 % |
| November | 27180,8 | 26761,5 | -1,5 % |
| Dicember | 23852,5 | 23416,4 | -1,8 % |
| Year | 492819,3 | 490119,2 | -0,5 % |

ELECTRICAL CABLES AND WIRINGS

The electrical wiring will be done using cables with insulated copper conductors with the following requirements:

- Section cores of copper calculated in accordance with rules IEC
- Type FG21 if outdoors or FG7 if in underground conduits
- Type N07V-K if inside conduits within buildings

To ensure the safety of those working on the plant during the verification, or adjustment, or the maintenance, the conductors will have the following colors:

- Protection conductor: yellow-green (mandatory)
- Neutral conductor: light blue (mandatory)
- Phase conductor: grey / brown
- Conductor for DC circuits: signed with a clear indication of the positive "+" and negative "-"

As it is possible to see from the above requirements, conductor cross-sections of the photovoltaic systems are certainly oversized for the current and the limited distances involved. With these sections the voltage drop is contained within 2% of the measured value from any module to the conversion system.

Wiring: **String cable**

| Description | Value |
|-----------------------------------|---|
| Identification: | FG21M21 1x4 red FG21M21 1x4 black |
| Total length: | 1320 m |
| Dimensioning length: | 20 m |
| Proximity circuits: | 1 |
| Ambient temperature: | 30° |
| Table: | IEC 60364-5-52 Ed.3 |
| Lay: | 4(B1) - Insulated conductors or single-core cables in conduit on a wooden or masonry wall |
| Disposition: | Bunched in air, on a surface, embedded or enclosed |
| Type of cable: | Single-core |
| Material: | Copper |
| Designation: | FG21M21 (1800Vcc) |
| Type of insulation: | PVC |
| Formation: | 2x(1x4) |
| N° conductors positive/phase: | 1 |
| Sect. positive/phase: | 4 mm ² |
| N° conductors negative/neutral: | 1 |
| Sect. negative/neutral: | 4 mm ² |
| N° conductors PE: | |
| Sect. PE: | |
| Rated voltage: | 608 V |
| Working current: | 8,6 A |
| Short-circuit current of modules: | 91,2 A |

Wiring: **String - Field C.**

| Description | Value |
|-----------------------------------|--|
| Identification: | FG7R 0.6/1 kV - 1X6 FG7R 0.6/1 kV - 1X6 |
| Total length: | 2949,09 m |
| Dimensioning length: | 71,34 m |
| Proximity circuits: | 1 |
| Ambient temperature: | 30° |
| Table: | IEC 60364-5-52 Ed.3 |
| Lay: | 71 (D1) - Single-core cable in conduit or in cable ducting in the ground |
| Disposition: | Bunched in air, on a surface, embedded or enclosed |
| Type of cable: | Single-core |
| Material: | Copper |
| Designation: | FG7R 0.6/1 kV |
| Type of insulation: | EPR |
| Formation: | 2x(1x6) |
| N° conductors positive/phase: | 1 |
| Sect. positive/phase: | 6 mm ² |
| N° conductors negative/neutral: | 1 |
| Sect. negative/neutral: | 6 mm ² |
| N° conductors PE: | |
| Sect. PE: | |
| Rated voltage: | 608 V |
| Working current: | 8,6 A |
| Short-circuit current of modules: | 91,2 A |

Wiring: **Field C. - Inverter C.**

| Description | Value |
|-------------------------------|--|
| Identification: | FG7R 0.6/1 kV - 1X70 FG7R 0.6/1 kV - 1X70 |
| Total length: | 213,07 m |
| Dimensioning length: | 59,73 m |
| Proximity circuits: | 4 |
| Ambient temperature: | 30° |
| Table: | IEC 60364-5-52 Ed.3 |
| Lay: | 71 (D1) - Single-core cable in conduit or in cable ducting in the ground |
| Disposition: | Bunched in air, on a surface, embedded or enclosed |
| Type of cable: | Single-core |
| Material: | Copper |
| Designation: | FG7R 0.6/1 kV |
| Type of insulation: | EPR |
| Formation: | 2x(1x70) |
| N° conductors positive/phase: | 1 |
| Sect. positive/phase: | 70 mm ² |

| | |
|-----------------------------------|--------------------|
| N° conductors negative/neutral: | 1 |
| Sect. negative/neutral: | 70 mm ² |
| N° conductors PE: | |
| Sect. PE: | |
| Rated voltage: | 608 V |
| Working current: | 94,2 A |
| Short-circuit current of modules: | 100,3 A |

Wiring: **Inverter C. - Parallel C.**

| Description | Value |
|---------------------------------|--|
| Identification: | FG7R 0.6/1 kV - 1X95 FG7R 0.6/1 kV - 1X50 |
| Total length: | 14,46 m |
| Dimensioning length: | 6,19 m |
| Proximity circuits: | 1 |
| Ambient temperature: | 30° |
| Table: | IEC 60364-5-52 Ed.3 |
| Lay: | 30(C) - Single-core cables on unperforated tray run horizontally or vertically |
| Disposition: | Bunched in air, on a surface, embedded or enclosed |
| Type of cable: | Single-core |
| Material: | Copper |
| Designation: | FG7R 0.6/1 kV |
| Type of insulation: | EPR |
| Formation: | 3x(1x95)+1G50 |
| N° conductors positive/phase: | 1 |
| Sect. positive/phase: | 95 mm ² |
| N° conductors negative/neutral: | 0 |
| Sect. negative/neutral: | 50 mm ² |
| N° conductors PE: | 1 |
| Sect. PE: | 50 mm ² |
| Rated voltage: | 320 V |
| Working current: | 198,4 A |

Wiring: **Parallel C. - Meter C.**

| Description | Value |
|----------------------|---|
| Identification: | FG7R 0.6/1 kV - 1X185 FG7R 0.6/1 kV - 1X50 |
| Total length: | 1,24 m |
| Dimensioning length: | 1,24 m |
| Proximity circuits: | 1 |
| Ambient temperature: | 30° |
| Table: | IEC 60364-5-52 Ed.3 |
| Lay: | 4(B1) - Insulated conductors or single-core cables in conduit on a wooden or masonry wall |
| Disposition: | Bunched in air, on a surface, embedded or enclosed |

| | |
|---------------------------------|---------------------|
| Type of cable: | Single-core |
| Material: | Copper |
| Designation: | FG7R 0.6/1 kV |
| Type of insulation: | EPR |
| Formation: | 3x(3x185)+1G50 |
| N° conductors positive/phase: | 3 |
| Sect. positive/phase: | 185 mm ² |
| N° conductors negative/neutral: | 0 |
| Sect. negative/neutral: | 95 mm ² |
| N° conductors PE: | 1 |
| Sect. PE: | 50 mm ² |
| Rated voltage: | 320 V |
| Working current: | 595,3 A |

Wiring: **Meter C. - LV/MV Cabinet**

| Description | Value |
|---------------------------------|--|
| Identification: | FG7R 0.6/1 kV - 1X185 FG7R 0.6/1 kV - 1X50 |
| Total length: | 10 m |
| Dimensioning length: | 10 m |
| Proximity circuits: | 1 |
| Ambient temperature: | 25° |
| Table: | IEC 60364-5-52 Ed.3 |
| Lay: | 30(C) - Single-core cables on unperforated tray run horizontally or vertically |
| Disposition: | Bunched in air, on a surface, embedded or enclosed |
| Type of cable: | Single-core |
| Material: | Copper |
| Designation: | FG7R 0.6/1 kV |
| Type of insulation: | EPR |
| Formation: | 3x(3x185)+1G50 |
| N° conductors positive/phase: | 3 |
| Sect. positive/phase: | 185 mm ² |
| N° conductors negative/neutral: | 0 |
| Sect. negative/neutral: | 95 mm ² |
| N° conductors PE: | 1 |
| Sect. PE: | 50 mm ² |
| Rated voltage: | 320 V |
| Working current: | 595,3 A |

| Table of cables | | | | | | | |
|-----------------|--------------------|---------|-------------------|------------------------|----------|----------|---------|
| Ref-mark | Description | Form. | Des. | Code | Origin | Dest. | Lc |
| W00 | String cable 1 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 1 | 20 m |
| W01 | String cable 1-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 1 | Q.1 | 59,97 m |
| W02 | String cable 2 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 2 | 20 m |
| W03 | String cable 2-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 2 | Q.1 | 40,33 m |

| | | | | | | | |
|-----|---------------------|---------|----------------------|------------------------|-----------|-----------|---------|
| W04 | String cable 3 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 3 | 20 m |
| W05 | String cable 3-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 3 | Q.1 | 20,69 m |
| W06 | String cable 4 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 4 | 20 m |
| W07 | String cable 4-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 4 | Q.1 | 62,81 m |
| W08 | String cable 5 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 5 | 20 m |
| W09 | String cable 5-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 5 | Q.1 | 43,17 m |
| W10 | String cable 6 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 6 | 20 m |
| W11 | String cable 6-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 6 | Q.1 | 23,53 m |
| W12 | String cable 7 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 7 | 20 m |
| W13 | String cable 7-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 7 | Q.1 | 65,66 m |
| W14 | String cable 8 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 8 | 20 m |
| W15 | String cable 8-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 8 | Q.1 | 46,02 m |
| W16 | String cable 9 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 9 | 20 m |
| W17 | String cable 9-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 9 | Q.1 | 26,38 m |
| W18 | String cable 10 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 10 | 20 m |
| W19 | String cable 10-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 10 | Q.1 | 68,5 m |
| W20 | String cable 11 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 11 | 20 m |
| W21 | String cable 11-Q.1 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 11 | Q.1 | 48,86 m |
| W22 | String cable 12 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 12 | 20 m |
| W23 | String cable 12-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 12 | Q.2 | 23,54 m |
| W24 | String cable 13 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 13 | 20 m |
| W25 | String cable 13-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 13 | Q.2 | 59,97 m |
| W26 | String cable 14 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 14 | 20 m |
| W27 | String cable 14-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 14 | Q.2 | 40,33 m |
| W28 | String cable 15 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 15 | 20 m |
| W29 | String cable 15-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 15 | Q.2 | 20,69 m |
| W30 | String cable 16 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 16 | 20 m |
| W31 | String cable 16-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 16 | Q.2 | 62,81 m |
| W32 | String cable 17 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 17 | 20 m |
| W33 | String cable 17-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 17 | Q.2 | 43,17 m |
| W34 | String cable 18 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 18 | 20 m |
| W35 | String cable 18-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 18 | Q.2 | 23,53 m |
| W36 | String cable 19 | 2x(1x4) | FG21M21 | CVPRY193 | | String 19 | 20 m |

| | | | | | | | |
|-----|---------------------|---------|-------------------|------------------------|-----------|-----------|---------|
| | | | (1800Vcc) | CVPRY192 | | | |
| W37 | String cable 19-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 19 | Q.2 | 65,66 m |
| W38 | String cable 20 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 20 | 20 m |
| W39 | String cable 20-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 20 | Q.2 | 46,02 m |
| W40 | String cable 21 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 21 | 20 m |
| W41 | String cable 21-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 21 | Q.2 | 26,38 m |
| W42 | String cable 22 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 22 | 20 m |
| W43 | String cable 22-Q.2 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 22 | Q.2 | 68,51 m |
| W44 | String cable 23 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 23 | 20 m |
| W45 | String cable 23-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 23 | Q.3 | 40,33 m |
| W46 | String cable 24 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 24 | 20 m |
| W47 | String cable 24-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 24 | Q.3 | 20,69 m |
| W48 | String cable 25 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 25 | 20 m |
| W49 | String cable 25-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 25 | Q.3 | 62,82 m |
| W50 | String cable 26 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 26 | 20 m |
| W51 | String cable 26-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 26 | Q.3 | 43,18 m |
| W52 | String cable 27 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 27 | 20 m |
| W53 | String cable 27-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 27 | Q.3 | 23,54 m |
| W54 | String cable 28 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 28 | 20 m |
| W55 | String cable 28-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 28 | Q.3 | 65,66 m |
| W56 | String cable 29 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 29 | 20 m |
| W57 | String cable 29-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 29 | Q.3 | 46,02 m |
| W58 | String cable 30 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 30 | 20 m |
| W59 | String cable 30-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 30 | Q.3 | 26,38 m |
| W60 | String cable 31 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 31 | 20 m |
| W61 | String cable 31-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 31 | Q.3 | 68,5 m |
| W62 | String cable 32 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 32 | 20 m |
| W63 | String cable 32-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 32 | Q.3 | 48,86 m |
| W64 | String cable 33 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 33 | 20 m |
| W65 | String cable 33-Q.3 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 33 | Q.3 | 29,22 m |
| W66 | String cable 34 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 34 | 20 m |
| W67 | String cable 34-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 34 | Q.4 | 59,97 m |
| W68 | String cable 35 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 35 | 20 m |

| | | | | | | | |
|------|---------------------|---------|-------------------|------------------------|-----------|-----------|---------|
| W69 | String cable 35-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 35 | Q.4 | 40,33 m |
| W70 | String cable 36 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 36 | 20 m |
| W71 | String cable 36-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 36 | Q.4 | 20,69 m |
| W72 | String cable 37 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 37 | 20 m |
| W73 | String cable 37-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 37 | Q.4 | 62,82 m |
| W74 | String cable 38 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 38 | 20 m |
| W75 | String cable 38-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 38 | Q.4 | 43,18 m |
| W76 | String cable 39 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 39 | 20 m |
| W77 | String cable 39-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 39 | Q.4 | 23,54 m |
| W78 | String cable 40 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 40 | 20 m |
| W79 | String cable 40-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 40 | Q.4 | 65,66 m |
| W80 | String cable 41 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 41 | 20 m |
| W81 | String cable 41-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 41 | Q.4 | 46,02 m |
| W82 | String cable 42 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 42 | 20 m |
| W83 | String cable 42-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 42 | Q.4 | 26,38 m |
| W84 | String cable 43 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 43 | 20 m |
| W85 | String cable 43-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 43 | Q.4 | 68,51 m |
| W86 | String cable 44 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 44 | 20 m |
| W87 | String cable 44-Q.4 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 44 | Q.4 | 48,86 m |
| W88 | String cable 45 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 45 | 20 m |
| W89 | String cable 45-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 45 | Q.5 | 20,69 m |
| W90 | String cable 46 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 46 | 20 m |
| W91 | String cable 46-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 46 | Q.5 | 62,81 m |
| W92 | String cable 47 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 47 | 20 m |
| W93 | String cable 47-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 47 | Q.5 | 43,17 m |
| W94 | String cable 48 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 48 | 20 m |
| W95 | String cable 48-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 48 | Q.5 | 23,53 m |
| W96 | String cable 49 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 49 | 20 m |
| W97 | String cable 49-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 49 | Q.5 | 65,66 m |
| W98 | String cable 50 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 50 | 20 m |
| W99 | String cable 50-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 50 | Q.5 | 46,02 m |
| W100 | String cable 51 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 51 | 20 m |
| W101 | String cable 51-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 | String 51 | Q.5 | 26,38 m |

| | | | | | | | |
|------|------------------------|----------|-------------------|------------------------|-----------|--------------|---------|
| | | | kV | CVPIR1505 | | | |
| W102 | String cable 52 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 52 | 20 m |
| W103 | String cable 52-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 52 | Q.5 | 68,5 m |
| W104 | String cable 53 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 53 | 20 m |
| W105 | String cable 53-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 53 | Q.5 | 48,86 m |
| W106 | String cable 54 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 54 | 20 m |
| W107 | String cable 54-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 54 | Q.5 | 29,22 m |
| W108 | String cable 55 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 55 | 20 m |
| W109 | String cable 55-Q.5 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 55 | Q.5 | 71,34 m |
| W110 | String cable 56 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 56 | 20 m |
| W111 | String cable 56-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 56 | Q.6 | 40,33 m |
| W112 | String cable 57 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 57 | 20 m |
| W113 | String cable 57-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 57 | Q.6 | 20,69 m |
| W114 | String cable 58 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 58 | 20 m |
| W115 | String cable 58-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 58 | Q.6 | 62,82 m |
| W116 | String cable 59 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 59 | 20 m |
| W117 | String cable 59-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 59 | Q.6 | 43,18 m |
| W118 | String cable 60 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 60 | 20 m |
| W119 | String cable 60-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 60 | Q.6 | 23,54 m |
| W120 | String cable 61 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 61 | 20 m |
| W121 | String cable 61-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 61 | Q.6 | 65,66 m |
| W122 | String cable 62 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 62 | 20 m |
| W123 | String cable 62-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 62 | Q.6 | 46,02 m |
| W124 | String cable 63 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 63 | 20 m |
| W125 | String cable 63-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 63 | Q.6 | 26,38 m |
| W126 | String cable 64 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 64 | 20 m |
| W127 | String cable 64-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 64 | Q.6 | 68,51 m |
| W128 | String cable 65 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 65 | 20 m |
| W129 | String cable 65-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 65 | Q.6 | 48,87 m |
| W130 | String cable 66 | 2x(1x4) | FG21M21 (1800Vcc) | CVPRY193 CVPRY192 | | String 66 | 20 m |
| W131 | String cable 66-Q.6 | 2x(1x6) | FG7R 0.6/1 kV | CVPIR1505 CVPIR1505 | String 66 | Q.6 | 29,23 m |
| W132 | Cable Q.1-inverter I.1 | 2x(1x70) | FG7R 0.6/1 kV | CVPIR1511 CVPIR1511 | Q.1 | inverter I.1 | 11,27 m |
| W133 | Cable Q.2-inverter I.1 | 2x(1x70) | FG7R 0.6/1 kV | CVPIR1511 CVPIR1511 | Q.2 | inverter I.1 | 22,65 m |

| | | | | | | | |
|------|--------------------------|----------------|---------------|------------------------|--------------|--------------|---------|
| W134 | Cable Q.3-inverter I.2 | 2x(1x70) | FG7R 0.6/1 kV | CVPIR1511 CVPIR1511 | Q.3 | inverter I.2 | 29,83 m |
| W135 | Cable Q.4-inverter I.2 | 2x(1x70) | FG7R 0.6/1 kV | CVPIR1511 CVPIR1511 | Q.4 | inverter I.2 | 41,21 m |
| W136 | Cable Q.5-inverter I.3 | 2x(1x70) | FG7R 0.6/1 kV | CVPIR1511 CVPIR1511 | Q.5 | inverter I.3 | 48,37 m |
| W137 | Cable Q.6-inverter I.3 | 2x(1x70) | FG7R 0.6/1 kV | CVPIR1511 CVPIR1511 | Q.6 | inverter I.3 | 59,73 m |
| W138 | Cable inverter I.1-p.c.. | 3x(1x95)+1 G50 | FG7R 0.6/1 kV | CVPIR1512 CVPIR1510 | inverter I.1 | p.c.. | 3,46 m |
| W139 | Cable inverter I.2-p.c.. | 3x(1x95)+1 G50 | FG7R 0.6/1 kV | CVPIR1512 CVPIR1510 | inverter I.2 | p.c.. | 4,82 m |
| W140 | Cable inverter I.3-p.c.. | 3x(1x95)+1 G50 | FG7R 0.6/1 kV | CVPIR1512 CVPIR1510 | inverter I.3 | p.c.. | 6,19 m |
| W141 | Cable p.c.-m.c.. | 3x(3x185)+1G50 | FG7R 0.6/1 kV | CVPIR1515 CVPIR1510 | p.c. | m.c.. | 1,24 m |
| W142 | Meter C. - Power Grid | 3x(3x185)+1G50 | FG7R 0.6/1 kV | CVPIR1515 | Meter C. | Power Grid | 10 m |

| Summary Table of cables | | | | | |
|-------------------------|----------------------------|----------------|-------------------|-----------------------|-----------|
| Code | Manufacturer | Form. | Des. | Description | Lc |
| CVPRY193 | PIRELLI CAVI e SISTEMI SPA | 2x(1x4) | FG21M21 (1800Vcc) | FG21M21 1x4 red | 1320 m |
| CVPRY192 | PIRELLI CAVI e SISTEMI SPA | 2x(1x4) | FG21M21 (1800Vcc) | FG21M21 1x4 black | 1320 m |
| CVPIR1505 | PIRELLI CAVI e SISTEMI SPA | 2x(1x6) | FG7R 0.6/1 kV | FG7R 0.6/1 kV - 1X6 | 5898,18 m |
| CVPIR1511 | PIRELLI CAVI e SISTEMI SPA | 2x(1x70) | FG7R 0.6/1 kV | FG7R 0.6/1 kV - 1X70 | 426,14 m |
| CVPIR1512 | PIRELLI CAVI e SISTEMI SPA | 3x(1x95)+1G50 | FG7R 0.6/1 kV | FG7R 0.6/1 kV - 1X95 | 43,38 m |
| CVPIR1510 | PIRELLI CAVI e SISTEMI SPA | 3x(1x95)+1G50 | FG7R 0.6/1 kV | FG7R 0.6/1 kV - 1X50 | 14,46 m |
| CVPIR1515 | PIRELLI CAVI e SISTEMI SPA | 3x(3x185)+1G50 | FG7R 0.6/1 kV | FG7R 0.6/1 kV - 1X185 | 101,16 m |
| CVPIR1510 | PIRELLI CAVI e SISTEMI SPA | 3x(3x185)+1G50 | FG7R 0.6/1 kV | FG7R 0.6/1 kV - 1X50 | 11,24 m |

ELECTRICAL PANELS

- **Field cabinet for direct current side**

It is planned to install an upstream cabinet for each converter to the parallel connection of strings, sectioning, measuring and controlling of the output data from the generator.

- **Parallel cabinet for alternating current side**

It is planned to install an alternating parallel cabinet within a box located downstream of static converters for measurement, connection and control of the inverter output variables. Within this cabinet, the network interface system will be added, in addition of the output counter of the electricity distribution company Endesa.

GALVANIC SEPARATION AND GROUNDING

Must be provided electrical isolation between the DC plant and network, and this separation can be replaced by a protection sensitive to direct current if the total power production does not exceed 20 kW.

Technical solutions different from those suggested above, shall be adopted, provided in compliance with applicable laws and rules of good art.

The PV array will be operated as an IT system, or with no polarity connected to earth. The strings will be, formed by a series of individual photovoltaic modules and individually sectionable, equipped with a blocking diode and surge protectors.

For safety, if the user network or part of it is considered unfit to bear the greater intensity of current available (due to the contribution of the PV system), the network itself or the party concerned should be appropriately protected.

The support structure will be regularly connected to the existing earth.

MONITORING AND CONTROL SYSTEM (MCS)

The control and monitoring system, allows by using a computer and dedicated software, to query the plant at any time to verify the functionality of the installed inverters with the ability to view the technical data (voltage, current, power etc. ..) of each inverter.

It is also possible read all the electrical data of bygone days in the event log of the converter.

VERIFICATION

Once complete, the installer of the system will check the following technical and functional areas:

- correct operation of the photovoltaic plant in different conditions of power generated and in the manner provided by the group of conversion (power, power failure, etc.).
- electrical continuity and connections between modules;
- grounding of the masses and drains;
- isolation of electric circuits from the masses;

At startup of the photovoltaic system, the relationship between the energy or power produced into alternating current and the energy or power producible in alternating current (determined as a function of solar radiation incident on the surface of the modules, rated system and the operating temperature of the modules) must be at least greater than 0.78 when using inverter power up to 20 kW and 0.8 in the case of using higher power inverters, under the conditions of measurement and calculation methods described in EN 60904-2.

The generator Generator ground mounted satisfies the following conditions:

Voltage limits

Minimum voltage V_n to 70,00 °C (493,2 V) greater than V_{mpp} min. (485,0 V)

Maximum voltage V_n to -10,00 °C (697,3 V) lower than V_{mpp} max. (950,0 V)

No-load voltage V_o to -10,00 °C (839,3 V) lower than inverter maximum voltage (1000,0 V)

No-load voltage V_o to -10,00 °C (839,3 V) lower than maximum isolating voltage (1000,0 V)

Current limits

Input maximum current according to I_{sc} (100,3 A) lower than inverter maximum current (123,0 A)


Power limits

Power dimensioning (101,4%) between 80,0% and 120,0% [INV. 1/MPPT 1]

LAYOUT OF THE GENERATOR



SINGLE-LINE DIAGRAM OF THE PLANT



CONCLUSIONS

Must be issued and released by the installer the following documents:

- operating and maintenance guide, inclusive of the recommended schedule of maintenance;
- executive project in version "as built", accompanied by data sheets of installed material;
- statement of executed verifications and its outcome;
- certification issued by an accredited laboratory on the compliance with standard EN 61215 for crystalline silicon modules, and EN 61646 by thin film modules;
- certification issued by an accredited laboratory on the compliance of the dc/ac converter with current regulations;
- warranty statements relating to the equipment installed;
- warranty on entire system and its operating performance.

The installation company, as well as thoroughly build as described in this project, will perform all work in compliance with the rules of art.